

25/9/07

HUIKE RS-45 TRIAL RESULTS

CAPACITY (WATTS)

| Hour | R22 | RS-45 | Variance % |
|------|------|-------|------------|
| 1 | 4765 | 4718 | 99.01 |
| 2 | 4695 | 4677 | 99.62 |
| 3 | 4707 | 4701 | 99.87 |

CURRENT (AMPS)

| Hour | R22 | RS-45 | Variance % |
|------|------|-------|------------|
| 1 | 1760 | 1746 | 99.20 |
| 2 | 1759 | 1744 | 99.15 |
| 3 | 1760 | 1743 | 99.03 |